

SITE PREPARATION

AREA REQUIRED FOR TANK CONSTRUCTION

20,000 LITRES - 5 METRES
90,000 LITRES - 10 METRES
120,000 LITRES - 11 METRES

- *THE SITE MUST BE ON NATURAL GROUND (NO FILL)
- *THE SITE MUST BE FLAT & LEVEL
- *SATISFACTORY SITE PREPARATION ELIMINATES COSTLY & ANNOYING DELAYS
- *REASONABLE ACCESS IS REQUIRED FOR HEAVY VEHICLES
- *BASE MATERIAL TO BE SPREAD ON SITE
7mm BLUE METAL TO A DEPTH OF 50mm
(about 3.5 to 4 metres of material)

TANK DIMENSIONS

	HEIGHT	DIAMETER
20,000 LITRES	2.4M	3.3 M
90,000 LITRES	2.4 M	7.5 M
120,000 LITRES	2.4 M	8.5 M

TANK COMES COMPLETE WITH:

- *FULLY REINFORCED CONCRETE
- *CHOICE OF ROOFING, ZINCALUME, COLOURBOND OR CONCRETE
- *CONCRETE ROOF HAS 4 CONCRETE COLUMNS (90 + 120,000 LITRES)
- *HEAVY DUTY CONCRETE ROOF TO REQUIREMENTS
- *2" BRASS OUTLET, OR AS REQUIRED
- *THREE 4" PVC INLETS AND OVERFLOW
- *GATE VALVE (ABOVE GROUND TANKS)
- *25 YEAR WRITTEN GUARANTEE
- *OPTIONAL STEEL PLATE LOCKABLE MAN HOLE COVER \$550